

SECTION 00920

ADDENDUM

City of Grand Ledge
Ball Field Development Adjacent to Fitzgerald Park PHASE 1

ADDENDUM NO. 1

DATE: 1/25/2024

ENGINEER: Eng., Inc.
4063 Grand Oak Drive, Suite A109
Lansing, MI 48911

Drawing Revision No: N/A

Drawing Sheets Issued Herewith: N/A

Bids Due: Friday, February 2nd @ 1:00 p.m. Local Time Issued to all Plan Holders

This Addendum is part of the Contract Documents and modifies the previously issued Bidding Documents. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may result in rejection of the Bid.

ITEM NO. 1

Below are questions from prospective Bidders with answers following in **boldface**:

- Does all the fence have bottom rail? (I know the backstop does but what about the rest?) – **All fencing is to have a top rail and bottom rail.**
- Are the line posts to be 8' on center or 10' on center? (the backstop is 5' on center) – **Line posts to be 8' on center.**
- For the backstop: Do you want 6-gauge on the bottom 10' and then 9-gauge at the top 10'? Or do you want the entire backstop chain link to be 6-gauge? – **Entire back stop chain link to be 6-gauge.**

END OF SECTION