



PRESS STATEMENT

Contact: Dave Gutchess, Public Services Superintendent

Phone: (517) 627-2149

Email: dgutchess@cityofgrandledge.com

Website: www.cityofgrandledge.com

Sanitary Sewer Overflow Event

Grand Ledge, MI, August 12, 2021 – Due to the recent, significant amount of rainfall the City of Grand Ledge has experienced a sanitary sewer overflow on August 12, 2021, at the Grand Ledge Wastewater Treatment Plant Wet Weather EQ Basin which started overflowing at approximately 4:57 AM and concluded at 10:15 AM discharging 207,691 gallons of partially treated wastewater. All overflow water was discharged to the Grand River. The Michigan Department of Environment, Great Lakes, and Energy (EGLE), local health department, and local newspaper have been notified accordingly.



PRESS STATEMENT

Contact: Dave Gutchess, Public Services Superintendent

Phone: (517) 627-2149

Email: dgutchess@cityofgrandledge.com

Website: www.cityofgrandledge.com

Sanitary Sewer Overflow Event

Grand Ledge, MI, August 12, 2021 – Due to the recent, significant amount of rainfall the City of Grand Ledge has experienced a sanitary sewer overflow on August 12, 2021, at three discharge locations. The first location is West River Street lift station, this overflow started at approximately 3:26 AM and concluded at 6:29 AM discharging approximately 59,334 gallons of diluted wastewater. The Second location is East River St. at Manhole #211 which started overflowing at approximately 2:20 AM and concluded at 8:36 AM discharging approximately 376,640 gallons of diluted wastewater. The third is located at the Grand Ledge Wastewater Treatment Plant Wet Weather EQ Basin which started overflowing at approximately 4:57 AM and is currently still active with expectations of concluding within the next 24 hours. All overflow water was discharged to the Grand River. The Michigan Department of Environment, Great Lakes, and Energy (EGLE), local health department, and local newspaper have been notified accordingly.